

TYPICAL TRENCH SECTION

NOTES:

- 1. MIN COVER TO BE 4.5' BELOW OFFICIAL STREET GRADE.
- 2. TRENCH WALLS TO BE SUPPORTED AS REQUIRED BY OSHA.
- 3. PIPE SHALL BE BEDDED FROM 18" BELOW THE BOTTOM OF THE PIPE TO 12" ABOVE THE TOP OF THE PIPE.
- 4. TRENCH WIDTH SHALL NOT BE MORE THAN 16" NOR LESS THAN 12" WIDER THAN THE LARGEST OD OF PIPE.
- 5. COMPACTION SHALL BE IN ACCORDANCE WITH CHAPTER 7.
- 6. TAPPING SADDLES REQUIRED IN AREAS WHERE THE BEDDING SECTION IS USED.

DENVER WATER 1600 West 12th Avenue Denver, Colorado 80204 Phone(303)628-6000 Telecopier No.(303)628-6851	
TYPICAL TRENCH SECTION PIPELINES IN DIPPING BEDI	
Scale: _ NONE Date: _JUNE_15	95
Drawn: _ C.B.B Tr: Ck: _	
Approved: Approved: Dr127_N	o 35 _

REVISED 2004